



Certificate of Compliance

This certificate is issued for the following:

Centrifugal Fire Pumps (Axial Split-Case Type)

Models **BSP 150-310** and BSP 200-290
(see ratings on page 2)

Prepared for:

Bristol Fire Engineering L.L.C.
Al Quoz Industrial Area 3
P.O. Box 74582
Dubai, United Arab Emirates

FM Approvals Class: 1311

Approval Identification: 3059490

Approval Granted: January 11, 2017

To verify the product continues to be Approved please refer to www.approvalguide.com.

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, reading "D.B. Fuller".

David B. Fuller
AVP, Manager of Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group



Certificate of Compliance

Product	Rated Capacity, (gal/min)	Rated Capacity, (dm ³ /min)	Rated Net Head at Rated Capacity, psi	Rated Net Head at Rated Capacity, kPa	Rated Speed, r/min	Suction Inlet, dia., in.	Discharge Outlet, dia., in.	Stage(s)
BSP 150-310	400	1515	138-226	950-1560	2950	6	4	1
BSP 150-310	500	1875	137-225	945-1550	2950	6	4	1
BSP 150-310	750	2840	132-225	910-1550	2950	6	4	1
BSP 150-310	1000	3785	128-222	885-1530	2950	6	4	1
BSP 200-290	1000	3785	140-172	965-1185	2950	8	5	1
BSP 200-290	1250	4730	136-169	940-1165	2950	8	5	1
BSP 200-290	1500	5680	132-165	910-1140	2950	8	5	1



Member of the FM Global Group