

Certificate of Compliance

This certificate is issued for the following:

Fire Hydrant (Dry and Wet Barrel Type) for Private Fire Service

Models: KM1001 and KM1000

Prepared for:

Kirmary International LLC
91 Linden Ave
Irvington Township, New Jersey 07111
United States of America


Approval Standard: FM 1510, 1511 (December 2021)

Approval Identification: PR475437

Approval Granted: 22 December 2025

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, reading 'David B. Fuller'.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
One Technology Way
Norwood, MA 02062



Valves | Water Control Valves (OS&Y and NRS Gate Valves) | **Gate Valves, Inside Screw**

Model KM103-300, KM104-300

Product Description

Resilient Seated Gate Valves. 2 through 12 inch NPS. Model KM104-300 is available with indicator post flange. Available with the following end connections and rated working pressure:

Product Specification

Model No	Valve Size		Rated Working Pressure		End Connection
	in	(mm)	psi	(kPa)	
KM103-300	2, 2 1/2, 3, 4, 5, 6, 8, 10, 12	(50, 65, 80, 100, 125, 150, 200, 250, 300)	300	(2065)	Flange x Flange (ANSI)
KM104-300	4, 5, 6, 8, 10, 12	(100, 125, 150, 200, 250, 300)	300	(2065)	Flange x Flange (ANSI)

Details

Category	Gate Valves, Inside Screw
Class of Work	1120 - OS&Y and NRS Gate Valves
Approval Standard	FM 1120, 1130 - Fire Service Water Control Valves (OS&Y and NRS Type Gate Valves)
Certification Type	FM Approved
Listing Country	United States of America

Company

Kirmary International LLC
91 Linden Ave, Irvington
Township , New Jersey 07111
United States of America
<http://kirmary.com>



Additional Info

Automatic Sprinkler Systems

Valves

Gate Valves

Gate Valves, Inside Screw

Inside screw gate valves are used underground with indicator posts attached or as roadway box valves (curb box installation). FM Approved valves are available with a variety of end connections as indicated in the listings.

Valves having Ring-Tite, Fluid-Tite or Tyton-Joint connections should be anchored in place during installation. Unless otherwise noted in the listing, these valves have 175 psi (1205 kPa) rated working pressure.
