

CERTIFICATE OF COMPLIANCE

Certificate Number EX643
Report Reference EX643-20171207
Issue Date 2019-DECEMBER-06

Issued to: VIKING CORP
210 INDUSTRIAL PARK DR
HASTINGS MI 49058-9706

This certificate confirms that
representative samples of SPRINKLERS, AUTOMATIC AND OPEN
SEE ADDENDUM PAGE FOR MODELS

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL199 standard for Standard for Automatic Sprinklers for
Fire-Protection Service
ULC/ORD-C199-03 standard for ULC Other Recognized
Document for Automatic Sprinklers Fire Protection Service
UL 199D and ULC/ORD- C199D-03 standard for Outline of
Investigation for Guards for Sprinklers

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up
Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's
Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number EX643
Report Reference EX643-20171207
Issue Date 2019-DECEMBER-06

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Models/Product

Automatic sprinklers incorporating a glass bulb of the following models, types and temperature ratings:

Listing s	SIN	Response Type	Sprinkler Type	Nominal K-Factor	System Working Pressure, psig	Temperature Rating, °F
USL, CNL	VK100 1	SR	Upright	5.6	250	135, 155, 175, 200, 286, 360
USL, CNL	VK100 1	SR	Intermediate Level Upright	5.6	250	135, 155, 175, 200, 286, 360
USL, CNL	VK102 1	SR	Pendent	5.6	250	135, 155, 175, 200, 286, 360
USL, CNL	VK102 1	SR	Intermediate Level Pendent	5.6	250	135, 155, 175, 200, 286, 360
USL, CNL	VK118 1	SR	Conventional	5.6	175	135, 155, 175, 200, 286, 360
USL, CNL	VK120 1	SR	Conventional	8.0	175	135, 155, 175, 200, 286, 360
USL, CNL	VK200 1	SR	Intermediate Level Upright	8.0	175	135, 155, 175, 200, 286, 360
USL, CNL	VK120 2	SR	Conventional, ½ NPT	8.0	175	135, 155, 175, 200, 286, 360
USL, CNL	VK200 1	SR	Upright	8.0	175	135, 155, 175, 200, 286, 360
USL, CNL	VK200 2	SR	Upright, ½ NPT	8.0	175	135, 155, 175, 200, 286, 360
USL, CNL	VK200 2	SR	Intermediate Level Upright, ½ NPT	8.0	175	135, 155, 175, 200, 286, 360
USL, CNL	VK202 1	SR	Pendent	8.0	175	135, 155, 175, 200, 286, 360
USL, CNL	VK202 1	SR	Intermediate Level Pendent	8.0	175	135, 155, 175, 200, 286, 360
USL, CNL	VK202 2	SR	Pendent, ½ NPT	8.0	175	135, 155, 175, 200, 286, 360
USL, CNL	VK202 2	SR	Intermediate Level Pendent, ½ NPT	8.0	175	135, 155, 175, 200, 286, 360
USL, CNL	VK300 1	QR	Upright	5.6	250	135, 155, 175, 200, 286
USL, CNL	VK300 1	QR	Intermediate Level Upright	5.6	250	135, 155, 175, 200, 286

B. Mahlenz

Bruce Mahlenz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number EX643
Report Reference EX643-20171207
Issue Date 2019-DECEMBER-06

USL, CNL	VK302 1	QR	Pendent	5.6	250	135,155,175,2 00,286
USL, CNL	VK302 1	QR	Intermediate Level Pendent	5.6	250	135,155,175,2 00,286
USL, CNL	VK310 1	QR	Conventional	5.6	175	135,155,175,2 00,286
USL, CNL	VK350 1	QR	Upright	8.0	175	135,155,175,2 00,286
USL, CNL	VK350 1	QR	Intermediate Level Upright	8.0	175	135,155,175,2 00,286
USL, CNL	VK350 2	QR	Upright, ½ NPT	8.0	175	135,155,175,2 00,286
USL, CNL	VK350 2	QR	Intermediate Level Upright, ½ NPT	8.0	175	135,155,175,2 00,286
USL, CNL	VK352 1	QR	Pendent	8.0	175	135,155,175,2 00,286
USL, CNL	VK352 1	QR	Intermediate Level Pendent	8.0	175	135,155,175,2 00,286
USL, CNL	VK352 2	QR	Pendent, ½ NPT	8.0	175	135,155,175,2 00,286
USL, CNL	VK352 2	QR	Intermediate Level Pendent, ½ NPT	8.0	175	135,155,175,2 00,286
USL, CNL	VK354 1	QR	Conventional	8.0	175	135,155,175,2 00,286
USL, CNL	VK354 2	QR	Conventional, ½ NPT	8.0	175	135,155,175,2 00,286

B. Mahlenz

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



SIN VK4621

File Number: EX643

COMPANY

Viking Corp
5150 BELTWAY DR SE
CALEDONIA, MI 49316 United States

SIN INFO

VK4621
Glass Bulb Type

ATTRIBUTES				
Response Type	Sprinkler Type	Nom K-Factor, gpm/vpsi (L/min/vbar)	System Working Pressure	Corrosion Resistant
QR	Standard-Spray Sprinklers, Upright And Pendent	5.6 (80)	250 psig (1.7 Mpa)	Not Available

GENERAL	
Inlet Connection	
1/2 in. NPT	

STANDARD-SPRAY SPRINKLERS, UPRIGHT AND PENDENT		
Type	Sprinkler Temp Rating, °F (°C)	Cover Temp Rating, °F (°C)
Conc. Pendent	155 (68), 200 (93)	139 (59), 165 (73)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."