



Certificate of Compliance

This certificate is issued for the following:

Fire Hose Assemblies and Fire Hose Couplings

KM 350

Prepared for:

Kirmary International LLC
91 Linden Ave
Irvington Township, New Jersey 07111
USA

Approval Standard: FM 2111, 2131 (October 2014)

Approval Identification: PR467452

Approval Granted: 8 November 2023

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read "D.B. Fuller", is written over a horizontal line.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group



Fire Hose, Lined, Uncoupled, for Municipal and Industrial Use

COMPANY

Kirmary International LLC

91 Linden Ave
Irvington Township, NJ 07111 United States

EX29167

View model for additional information

Single-jacketed, Model(s): [KM 350](#)

Last Updated on 2023-10-25

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2023 UL LLC."

Cookies on UL Solutions

We use cookies to personalize content and ads, to provide social media features and to analyze our traffic. We also share information about your use of our site with our social media, advertising and analytics partners. [Learn more](#)

[Cookies Settings](#)

[Reject All](#)

[Accept All Cookies](#)

Model KM 350

File Number: EX29167

COMPANY

Kirmary International LLC

91 Linden Ave
Irvington Township, NJ 07111 United States

MODEL INFO

KM 350

Single-jacketed

HOSE INFORMATION

| Hose Size, in. (mm) | Service Test Pressure, psig (kPa) | Ratings | Comments |
|---------------------|-----------------------------------|---------|---|
| 1-1/2 (38) | 250 (1725) | -- | EPDM Lining, Synthetic Polyester Jacket |
| 2-1/2 (65) | 250 (1725) | -- | EPDM Lining, Synthetic Polyester Jacket |

CONDUCTIVE HEAT EXPOSURE: STEEL BLOCK AT 400°C (752°F)

| Hose Size, in. (mm) | Exposure Duration | Avg Leakage Rate @ 150 psi | Max Leakage Rate @ 150 psi |
|---------------------|-------------------|----------------------------|----------------------------|
| 1-1/2 (38) | 2 sec | > 20 gpm | > 20 gpm |
| 2-1/2 (65) | 2 sec | > 20 gpm | > 20 gpm |

RADIANT HEAT EXPOSURE: 30 KW/M2

| Hose Size, in. (mm) | Color/Marking | Exposure Duration | Avg Leakage Rate @ 150psi | Max Leakage Rate @ 150 psi |
|---------------------|---------------|-------------------|---------------------------|----------------------------|
| 1-1/2 (38) | White | 10 min 20 sec | 9 gpm | > 20 gpm |
| 2-1/2 (65) | White | 5 min 55 sec | > 20 gpm | > 20 gpm |

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2023 UL LLC."

Cookies on UL Solutions

We use cookies to personalize content and ads, to provide social media features and to analyze our traffic. We also share information about your use of our site with our social media, advertising and analytics partners. [Learn more](#)

Certificate of Product Approval

Certificate Number: 1127a

Issue: 03

Power Saints Ltd.

Tianhua Industrial District
Langxia Street Scene
Yuyao City
Zhejiang
315480
China

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Products

'Krone' Fire Hose Reels

Standards

EN 671-1:2012

Fixed firefighting systems. Hose systems. Hose reels with semi-rigid hose

This certificate and appendix is maintained and held in force through regular surveillance activities

J. Mit.

Signed for LPCB

Joe Milton

Verifier

02 December 2015

Date of Issue

26 June 2012

Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre

Appendix to Certificate No: 1127a Power Saints Ltd.

Issue: 03

'Krone' Fire Hose Reels to EN 671-1:2012

| Product Name | Description | Hose Nominal Bore (mm) | Hose Maximum Length (m) | Nozzle type | LPCB Ref. No. |
|---------------|--|------------------------|-------------------------|---|---------------|
| SA10-314D-03S | Automatic, swinging arm, wall mounted | 25 | 30 | Rotary operated jet/spray | 1127a/01 |
| SA10-314D-02S | Manual, swinging arm, wall mounted | 25 | 30 | Rotary operated jet/spray | 1127a/02 |
| SA10-314D-14F | Manual, fixed, wall mounted | 25 | 30 | Rotary operated jet/spray | 1127a/03 |
| SA10-304D-03S | Automatic, swinging arm, wall mounted | 19 | 30 | Rotary operated jet/spray | 1127a/04 |
| SA10-304D-02S | Manual, swinging arm, wall mounted | 19 | 30 | Rotary operated jet/spray | 1127a/05 |
| SA10-304D-14F | Manual, fixed, wall mounted | 19 | 30 | Rotary operated jet/spray | 1127a/06 |
| PSHR3330SF | Manual, swinging arm, pillar or wall mounted | 33 | 30 | Rotary operated jet/spray or lever operated jet/spray | 1127a/07 |

This certificate and appendix is maintained and held in force through regular surveillance activities

J. Mit.

Signed for LPCB

Joe Milton
Verifier

02 December 2015
Date of Issue

26 June 2012
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR Tag or contact us.

LPCB is part of BRE Global Ltd., Garston, Watford WD25 9XX.
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: Enquiries@breglobal.com



bre

Certificate of Product Approval

Certificate Number: 1153c

Issue: 01

Ningbo Jintian Fire Fighting Industrial Co., Ltd.

Wu Che Yan
Yuyao City
Zhejiang Province
China



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Products

'JINTIAN FIRE' Hand-Held Branchpipes
(refer to attached appendix for details)

Standards

EN 15182-1:2007+A1:2009

Hand-held branchpipes for fire service use – Part 1: Common requirements

EN 15182-3:2007+A1:2009

Hand-held branchpipes for fire service use – Part 3: Smooth bore jet and/or one fixed spray angle branchpipes PN16

This certificate and appendix is maintained and held in force through regular surveillance activities

Signed for LPCB

Joe Milton
Verifier

20 February 2017
Date of Issue

20 February 2017
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



Appendix to Certificate No: 1153c Ningbo Jintian Fire Fighting Industrial Co., Ltd.

Issue: 01

'JINTIAN FIRE' Hand-Held Branchpipes to EN 15182-1:2007+A1:2009 and EN 15182-3:2007+A1:2009

| Product Name | Description | LPCB Ref. No. |
|--------------|---|---------------|
| KX07-108C-00 | 13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, 2" BSP threaded male inlet, hand-held branchpipe | 1153c/01 |
| KX07-108A-00 | 13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, M56 x 4 threaded female inlet, hand-held branchpipe | 1153c/02 |
| KX07-127F-00 | 13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, BS336 male inlet, hand-held branchpipe | 1153c/03 |
| KX07-108D-00 | 13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, 2" BSP threaded male inlet, hand-held branchpipe | 1153c/04 |
| KX07-108B-00 | 13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, M56 x 4 threaded female inlet, hand-held branchpipe | 1153c/05 |
| KX07-127E-00 | 13mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, BS336 male inlet, hand-held branchpipe | 1153c/06 |

This certificate and appendix is maintained and held in force through regular surveillance activities



Signed for LPCB

Joe Milton
Verifier

20 February 2017
Date of Issue

20 February 2017
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR Tag or contact us.

LPCB is part of BRE Global Ltd., Garston, Watford WD25 9XX.

T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: Enquiries@breglobal.com




Appendix to Certificate No: 1153c Ningbo Jintian Fire Fighting Industrial Co., Ltd.

Issue: 01

'JINTIAN FIRE' Hand-held Branchpipes to EN 15182-1:2007+A1:2009 and EN 15182-3:2007+A1:2009

| Product Name | Description | LPCB Ref. No. |
|--------------|--|---------------|
| KX07-107C-00 | 16mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, 2½" BSP threaded male inlet, hand-held branchpipe | 1153c/07 |
| KX07-107A-00 | 16mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever and shaft gripping device, plastics obturator, M85*6*6H threaded female inlet, hand-held branchpipe | 1153c/08 |
| KX07-107D-00 | 16mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, 2½" BSP threaded male inlet, hand-held branchpipe | 1153c/09 |
| KX07-107B-00 | 16mm smooth bore, straight jet and one fixed spray jet, lever operated, aluminium body, plastics covered aluminium lever, plastics shaft gripping device and obturator, M85*6*6H threaded female inlet, hand-held branchpipe | 1153c/10 |

This certificate and appendix is maintained and held in force through regular surveillance activities

J. Mit.

Signed for LPCB

Joe Milton
Verifier

20 February 2017
Date of Issue

20 February 2017
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR Tag or contact us.

LPCB is part of BRE Global Ltd., Garston, Watford WD25 9XX.

T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: Enquiries@breglobal.com



bre



Kitemark™ Licence

This is to certify that:

Ningbo Jintian Fire Fighting Industrial Co Ltd

WuCheYan
Yuyao City
315466
China

Holds Kitemark Licence Number:

KM 583674

In respect of:

Fire hose couplings and ancillary equipment

This issues the right and Licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Licence shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Licence provided at or from the above address.

For and on behalf of BSI:

Gary Fenton, Global Assurance Director

First Issued: 11/04/2013

Latest Issue: 11/04/2013



No. KM 583674

BS 336:2010 - Fire Hose Couplings & Ancillary Equipment

| Model | Description |
|---------------|--|
| KX07-131A-00 | Controllable branch-pipe |
| KX07-131B-00 | Controllable branch-pipe |
| KX07-131C-00 | Controllable branch-pipe |
| KX08-201A-00 | 2½" aluminium delivery hose coupling with a 2¾" ribbed tail |
| KX08-201A1-00 | 2½" aluminium delivery hose coupling with a 2½" ribbed tail |
| KX08-201A2-00 | 2½" aluminium delivery hose coupling with a 2" ribbed tail |
| KX08-201A3-00 | 2½" aluminium delivery hose coupling with a 1¾" ribbed tail |
| KX08-201A4-00 | 2½" aluminium delivery hose coupling with a 1½" ribbed tail |
| KX08-201B-00 | 2½" copper alloy delivery hose coupling with a 2¾" ribbed tail |
| KX08-201B1-00 | 2½" copper alloy delivery hose coupling with a 2½" ribbed tail |
| KX08-201B2-00 | 2½" copper alloy delivery hose coupling with a 2" ribbed tail |
| KX08-201B3-00 | 2½" copper alloy delivery hose coupling with a 1¾" ribbed tail |
| KX08-201B4-00 | 2½" copper alloy delivery hose coupling with a 1½" ribbed tail |
| KX08-201C-00 | 2½" copper alloy delivery hose coupling with a 2¾" ribbed tail |
| KX08-201C1-00 | 2½" copper alloy delivery hose coupling with a 2½" ribbed tail |
| KX08-201C2-00 | 2½" copper alloy delivery hose coupling with a 2" ribbed tail |
| KX08-201C3-00 | 2½" copper alloy delivery hose coupling with a 1¾" ribbed tail |
| KX08-201C4-00 | 2½" copper alloy delivery hose coupling with a 1½" ribbed tail |

First Issued: 11/04/2013

Latest Issue: 11/04/2013



Certificate of Compliance

This certificate is issued for the following:

Angle and Straightaway Hose Valves

KM300

Prepared for:

Kirmary International LLC

91 Linden Ave

Irvington Township, New Jersey 07111

USA

Approval Standard: FM 1521, 1522 (December 2014)

Approval Identification: PR465870

Approval Granted: 3 May 2023

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read 'D.B. Fuller', written over a horizontal line.

David B. Fuller

VP, Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062



Member of the FM Global Group



VTSR.EX29020 - Hose Valves

Hose Valves

Kirmary International LLC

EX29020

91 Linden Ave
Irvington, NJ 07111-2562 United States

Angle types, 1-1/2, with female/female (NPT/NPS) and female/male (NPS) ends. for a maximum working pressure of 300 psi, for use on a fire hose rack assembly, or as a fire department outlet connection, Model(s) **KM300**

Angle types, 2-1/2 in., with female/female (NPT/NPS), female/male (NPS), Female NPT/Male NYC, GRV by Male NH, GRV by Male NYC and Male NH by Male NYC for a maximum working pressure of 300 psi, for use on a fire hose rack assembly, or as a fire department outlet connection, Model(s) KM300

Trademark and/or Tradename:



, "KIRMARY"

Last Updated on 2023-04-05

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2023 UL LLC."

إيماء لكتاب الشركة المتخصصة للتوريدات وأعمال المقاولات الوارد للإدارة بشأن طلب فحص صندوق حريق بمشتملاته ٢.٥" وكذا صندوق هوزريل ١" لتوريدهما لمشروع مستشفى الساحل التعليمي وكذا مشروع مصنع قطونيل الخانكة .

وبناء على ما تأثر من السيد اللواء / وكيل الإدارة للإطفاء لإدارة هندسة الإطفاء وإدارة الحماية المدنية في الصناعة للدراسة والفحص فقد تشكلت لجنة برئاسة السيد العقيد / ماجد محمد عبدالخالق

- مدير ادارة الحماية المدنية في الصناعة وعضوية كلاً من :-

- السيد المقدم / احمد حسن خطاب - مدير إدارة هندسة الاطفاء

- السيد النقيب / رامى محمد الرمى - إدارة هندسة الاطفاء

* بدراسة المرفقات تبين الاتى :-

اولا : عقد مقاوله بتاريخ ١٥ / ١٢ / ٢٠١٦ بين مصنع قطونيل الكائن بمدينة الخانكة (طرف اول) والشركة المتخصصة للتوريدات وأعمال المقاولات (طرف ثان) ومن ضمن بنود العقد توريد الاتى :

١ - عدد (٣٧) حنفية حريق قطر ٢.٥ بوصة طراز موريس .

٢ - عدد (٣٧) صندوق حريق بمشتملاته (خرطوم ٢.٥ بوصة + قاذف متعدد الأغراض ٢.٥") .

٣ - عدد (٦١) صندوق حريق هوزريل كامل قطر ١ بوصة .

ثانيا : عقد مقاوله بتاريخ ١٨ / ٤ / ٢٠١٨ بين مستشفى الساحل التعليمي (طرف اول) والشركة المتخصصة للتوريدات واعمال المقاولات (طرف ثان) ومن ضمن بنود العقد توريد الاتى :

١ - عدد (٢٠) حنفية حريق قطر ٢.٥ بوصة .

٢ - عدد (٢٠) صندوق حريق بمشتملاته (خرطوم ٢.٥ بوصة + قاذف متعدد الاغراض ٢.٥") .

٣ - عدد (٥٠) صندوق حريق هوزريل كامل قطر



Handwritten signature in blue ink.



* قامت اللجنة بفحص الاتي :-

* بالنسبة لصندوق خراطيم الحريق صناعة مصرية مقاس ٨٠ سم X ٨٠ سم X ٣٠ سم

مقدم عينة لصندوق حريق تصميم الشركة المتخصصة ٨٠ سم X ٨٠ سم X ٣٠ سم ، سمك ١.٥ مم

* بالنسبة لقاذف إطفاء ٢.٥" يعطي المياه (عمود - مستمر - رذاذ) :-

- مقدم كتالوج لقاذف إطفاء ماركة JINTIAN FIRE طراز KX07-127F-00 وكتالوج لقاذف إطفاء ماركة JINTIAN FIRE طراز KX07-131C-00 موضح به أن القاذف يعطي معدل تصريف ٢٥٠ لتر / دقيقة عند ٧ بار
- مقدم شهادة من معمل LPCB برقم 1153C تفيد مطابقة القاذف للمواصفات الأوروبية EN15182-1:2007+A1:2009 وكذا المواصفات الأوروبية EN15182-3:2007+A1:2009 ومطابقة اللاكور للمواصفات BS336 وذلك للطراز KX07-127F-00 .
- مقدم شهادة من معمل (KITMARK) BSI برقم KM583674 تفيد مطابقة القاذف للمواصفات الانجليزية ومطابقة اللاكور للمواصفات BS336 وذلك للطراز KX07-131C-00 .

* بالنسبة لحنفية إطفاء حائطية قطر ٢.٥ بوصة :-

- مقدم كتالوج لحنفية حائطية ٢.٥ بوصة ماركة HUACHENG طراز HC- (DWG.J281) 102 موضح به ان الحنفية حاصلة على اعتماد من معمل UL يفيد مطابقة الحنفية للمواصفات الاوروبية .
- مقدم شهادة من معمل UL برقم VTSR.EX16364 تفيد مطابقة الحنفية للمواصفات الاوروبية .



*** بالنسبة لخرطوم حريق ٢.٥ بوصة مبطن من الداخل فقط بالواكير ٢.٥ بوصة أبيض اللون :-**

- مقدم كتالوج لخرطوم ٢.٥ بوصة مبطن من الداخل فقط بلواكير ٢.٥ بوصة بلون أبيض موضح به ان الخرطوم ماركة ZYFIRE وضغط التشغيل ١٧ بار والضغط الانفجاري ٥١ بار وحاصل على شهادة FM APPROVED واللواكير مطابقة للمواصفات BS336

- مقدم تقرير الاختبارات التي تمت بالمركز القومي للبحوث برقم MOI 9321 05 2018 موضح به أن الخرطوم إنتاج شركة زيفاير بالصين استيراد شركة كيرمارى للتوريدات الهندسية وقد تمت عليه الإختبارات الآتية

- ١- إختبار الأبعاد
- ٢- إختبار وزن المتر الطولي
- ٣- إختبار الضغط الهيدروستاتيكي
- ٤- إختبار الإلتواء تحت ضغط
- ٥- إختبار ضغط الانفجار
- ٦- إختبار المرونة
- ٧- إختبار المعالجة الحرارية
- ٨- إختبار تأثير الأوزون
- ٩- إختبار الإحتكاك

وقد اجتاز الخرطوم حدود المواصفة BS6391 TYPE1 والمواصفة المصرية رقم ٣٥١٣ نوع ١.

*** بالنسبة لخرطوم حريق قطر ٢.٥ بوصة مبطن من الداخل فقط بلواكير ٢.٥ بوصة أحمر اللون :-**

- مقدم كتالوج لخرطوم ٢.٥ بوصة مبطن من الداخل فقط بلواكير ٢.٥ بوصة بلون احمر موضح به أن الخرطوم ماركة ZYFIRE وضغط التشغيل ١٧ بار والضغط الانفجاري ٥١ بار وحاصل على شهادة FM APPROVED واللواكير مطابقة للمواصفات BS336

- مقدم تقرير الاختبارات التي تمت بالمركز القومي للبحوث برقم MOI 9321 05 2018 موضح به أن

الخرطوم إنتاج شركة زيفاير بالصين استيراد شركة كيرمارى للتوريدات الهندسية وقد تمت عليه الإختبارات السابق ذكرها أعلاه

وقد اجتاز الخرطوم حدود المواصفة BS6391 TYPE 2 والمواصفة المصرية رقم ٣٥١٣ نوع ٢



(Handwritten signature)



* الرأي :-

الإدارة ليس لديها مانع من تركيب كلا من :

- صندوق حريق تصميم الشركة المتخصصة بإبعاد ٨٠سم X ٨٠سم X ٣٠سم سمك ١.٥مم.
- قاذف إطفاء ماركة JINTIAN FIRE طراز KX07-127F-00 وكذا طراز KX07-131C-00 .
- حنفية حائطية قطر ٢.٥ بوصة ماركة HUACHENG طراز (DWG.J281) HC-108 .
- هوزريل إطفاء قطر ١ بوصة ماركة EZULA طراز EX06-173B-00 .
- على ان يتم التركيب وفقا لما هو وارد بالكود المصرى للحريق وتحت اشراف استشارى المشروع .
- وبالنسبة لخرطوم إطفاء ٢.٥ بوصة مبطن من الداخل فقط بلواكير ٢.٥ بوصة بلون ابيض (TYPE1
- ماركة ZYFIRE وضغط التشغيل ١٧ بار والضغط الانفجاري ٥١ بار وكذا خرطوم ٢.٥ بوصة مبطن
- من الداخل فقط بلواكير ٢.٥ بوصة بلون احمر (TYPE2) ماركة ZYFIRE وضغط التشغيل ١٧

بار والضغط الانفجاري ٥١ بار فالإستشارى وشأنه .

وهذا تقرير منا بذلك

٢٠١٨/٧/١٢

أعضاء اللجنة :

نقيب / رامى محمد رامى

مقدم / أحمد حسن خطاب



رئيس اللجنة :

عقيد / ماجد محمد عبد الخالق

مدير ادارة الحماية المدنية في الصناعة



G.A.C.P

السادة / الشركة المتخصصة للتوريدات وأعمال المقاولات

تحية طيبة... وبعد ؛

تهدي الإدارة العامة للحماية المدنية أطيب تحياتها لسيادتكم مقرونة باسمى ايات التقدير

ايماء لكتاب سيادتكم الوارد للإدارة بشأن طلب فحص صندوق حريق بمشتملاته

لتوريده لمشروع مستشفى الساحل التعليمي وكذا مشروع مصنع قطنيل الخانكة .

نتشرف ان نرسل لسيادتكم التقرير المعد فى هذا الشأن .

وتفضلوا سيادتكم بقبول وافر الاحترام

٢٠١٨/٧/١٢
عبدالمقصود بدير
لإدارة




لواء /
عبدالمقصود بدير
٢٠١٨/٧/١٢

مدير الإدارة العامة للحماية المدنية



G.A.C.P



السادة / شركة كيرمارى

تحية طيبة... وبعد ؛

تهدى الإدارة العامة للحماية المدنية أطيب تحياتها لسيادتكم مقرونة باسمى ايات التقدير

ايحاء لكتاب سيادتكم الوارد للإدارة بشأن طلب فحص صندوق حريق فارغ (بدون مشتعلاته)

بمشروع البنك الاهلى (فرع العاصمة الادارية الجديدة) .

نتشرف ان نرسل لسيادتكم التقرير المعد فى هذا الشأن .

وتفضلوا سيادتكم بقبول وافر الاحترام

٢٠١٩/١٠/١٩



مدير الإدارة العامة للحماية المدنية



G.A.C.P

تقرير

ايحاء لكتاب شركة كيرمارى الوارد للادارة بشأن طلب فحص صندوق حريق فارغ (بدون مشتملاته) بمشروع البنك الاهلى (فرع العاصمة الادارية الجديدة) .
وبناءً على ماتأثر من السيد اللواء / وكيل الادارة للاطفاء لادارة هندسة الاطفاء للفحص والدراسة فقد تم تشكيل لجنة برئاسة السيد العميد/ ماجد محمد عبدالخالق - مدير إدارة الحماية المدنية فى الصناعة وعضوية كلا من :

- السيد المقدم مهندس/ أحمد حسن خطاب
- مدير ادارة هندسة الاطفاء
- السيد النقيب مهندس/ رامى محمد الرامى
- ادارة هندسة الاطفاء

● بفحص المرفقات تبين الاتى :-

- مقدم مقايصة اعمال مختومة من المكتب الاستشارى (شاكر) موضح بها صندوق اطفاء حريق .
- الفحص :

١ . بالنسبة لصندوق اطفاء مفرد فارغ (بدون مشتملاته) :-

- مقدم عينة لصندوق اطفاء مفرد مقاس ٣٠*٨٠*٨٠ سم ماركة KIRMARY .
- *** الصنف مقبول من الناحية الفنية .



٢ . بالنسبة لصندوق اطفاء مزدوج فارغ (بدون مشتملاته) :-

- مقدم عينة لصندوق اطفاء مزدوج مقاس ٣٠*٨٠*١٦٠ سم ماركة KIRMARY .
- *** الصنف مقبول من الناحية الفنية .

• الرأى :-

ترى اللجنة انه لا مانع من تركيب الأصناف الآتية بمشروع البنك الاهلى (فرع العاصمة الادارية الجديدة) :

١. صندوق اطفاء مفرد فارغ (بدون مشتملاته) مقاس ٨٠*٨٠*٣٠ سم سمك ١.٥ مم ماركة

. KIRMARY

٢. صندوق اطفاء مزدوج فارغ (بدون مشتملاته) مقاس ١٦٠*٨٠*٣٠ سم سمك ١.٥ مم

ماركة KIRMARY .

على ان يتم التركيب وفقا لما هو وارد بالكود المصرى للحريق وتحت اشراف استشارى المشروع .

وهذا تقرير منا بذلك

٢٠١٩/١٠/١٩

اعضاء اللجنة :-

نقيب مهندس/ رامى محمد الرامى

مقدم مهندس/ أحمد حسن خطاب



رئيس اللجنة

عميد / ماجد محمد عبد الخالق

مدير ادارة الحماية المدنية فى الصناعة

DEPARTMENT OF THE TREASURY
UNITED STATES CUSTOMS SERVICE

NORTH AMERICAN FREE TRADE AGREEMENT
CERTIFICATE OF ORIGIN

Please print or type

19 CFR 181.11, 181.22


| | |
|--|---|
| <p>1. EXPORTER NAME AND ADDRESS KIRMARY INTERNATIONAL LLC AS AGENT FOR : ZYFIRE HOSE CORPORATION 91 LINDEN AVE .IRVINGTON, NJ. 07111 TEL: 201-852-2454 EMAIL: KIRMARY@KIRMARY.COM</p> <p>TAX IDENTIFICATION NUMBER: 93-1967673</p> | <p>2. BLANKET PERIOD (DDMMYY) DEC.20.2023</p> <p>FROM NEW YORK, USA</p> <p>TO SOKHNA PORT, EGYPT</p> |
| <p>3. PRODUCER NAME AND ADDRESS</p> <p>TAX IDENTIFICATION NUMBER:</p> | <p>4. IMPORTER NAME AND ADDRESS KIRMARY FOR ENGINEERING SUPPLIES 5A KHALED EBN EL WALEED ST SHERATON , CAIRO, EGYPT TEL: 0022-664920/30 EMAIL: INFO@KIRMARY.COM</p> <p>TAX IDENTIFICATION NUMBER: 349796378</p> |

| 5. DESCRIPTION OF GOOD(S) | 6. HS TARIFF CLASSIFICATION NUMBER | 7. PREFERENCE CRITERION | 8. PRODUCER | 9. NET COST | 10. COUNTRY OF ORIGIN |
|---|--|-------------------------|-------------|-------------|-----------------------|
| <p>EIGHTEEN (18) PACKAGES OF FIRE HOSE (W : 12962 KGS) ONE THOUSAND (1000) PACKAGES OF CARTONS (W: 1020 KGS) ONE HUNDRED AND FIVE (105) PACKAGES OF HOSE FITTINGS (W: 1092 KGS) EIGHT (8) PACKAGES OF RUBBER SLEEVES (W: 195 KGS) SIX (6) PACKAGES OF BINDING MACHINE (W : 590 KGS) SIXTY THREE (63) PACKAGES OF BRANCH PIPE (W: 781 KGS)</p> | <p>59090000 48191000 76090000 40093100 8479899990 84242000</p> | <p>23ZY010415</p> | <p>N.H</p> | <p>N/A</p> | <p>USA</p> |

KIRMARY BRAND

ASSEMBLED & TESTED IN USA

ACID 3497963782023080018
IMPORT TAX # : 349796378
EXPORTER # 913302266102641340
FOREIGN EXPORTER COUNTRY : USA
FOREIGN EXPORTER COUNTRY CODE : US



ALI I HASSANEIN
AI

Ali Hassanein
21-2024



**Woodbridge Metro
Chamber of Commerce**
178 Main Street
Woodbridge, NJ 07095
www.woodbridgechamber.com

Holly B Church Doyle

I CERTIFY THAT:

- THE INFORMATION ON THIS DOCUMENT IS TRUE AND ACCURATE AND I ASSUME THE RESPONSIBILITY FOR PROVING SUCH REPRESENTATIONS. I UNDERSTAND THAT I AM LIABLE FOR ANY FALSE STATEMENTS OR MATERIAL OMISSIONS MADE ON OR IN CONNECTION WITH THIS DOCUMENT;
- I AGREE TO MAINTAIN, AND PRESENT UPON REQUEST, DOCUMENTATION NECESSARY TO SUPPORT THIS CERTIFICATE, AND TO INFORM, IN WRITING, ALL PERSONS TO WHOM THE CERTIFICATE WAS GIVEN OF ANY CHANGES THAT COULD AFFECT THE ACCURACY OR VALIDITY OF THIS CERTIFICATE;
- THE GOODS ORIGINATED IN THE TERRITORY OF ONE OR MORE OF THE PARTIES, AND COMPLY WITH THE ORIGIN REQUIREMENTS SPECIFIED FOR THOSE GOODS IN THE NORTH AMERICAN FREE TRADE AGREEMENT, AND UNLESS SPECIFICALLY EXEMPTED IN ARTICLE 411 OR ANNEX 401, THERE HAS BEEN NO FURTHER PRODUCTION OR ANY OTHER OPERATION OUTSIDE THE TERRITORIES OF THE PARTIES; AND
- THIS CERTIFICATE CONSISTS OF 1 PAGES, INCLUDING ALL ATTACHMENTS.

| | |
|--------------------------------------|---|
| 11a. AUTHORIZED SIGNATURE | 11b. COMPANY KIRMARY INTERNATIONAL USA LLC. |
| 11c. NAME (Print or Type) | 11d. TITLE V.P |
| 11e. DATE (DDMMYY) DEC. 20 . 2023 | 11f. TELEPHONE NUMBER (Voice) +1-201-852-2454 (Facsimile) |